



Ernie Fletcher
Governor

LaJuana S. Wilcher, Secretary
Environmental and Public
Protection Cabinet

Christopher L. Lilly
Commissioner
Department of Public Protection

Charles D. Burton
President
Western Rockcastle Water Association, Inc.
P. O. Box 627
Mt. Vernon, KY 40456

Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615
Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

Mark David Goss
Chairman

Teresa J. Hill
Vice Chairman

Gregory Coker
Commissioner

April 18, 2006

CERTIFICATE OF SERVICE

RE: Case No. 2005-00542
Western Rockcastle Water Association, Inc.

I, Beth O'Donnell, Executive Director of the Public Service Commission, hereby certify that the enclosed attested copy of the Commission's Order in the above case was served upon the addressee by U.S. Mail on April 18, 2006.

Executive Director

BOD/sh
Enclosure

Charles D. Burton
President
Western Rockcastle Water
Association, Inc.
P. O. Box 627
Mt. Vernon, KY 40456

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WESTERN ROCKCASTLE)	
WATER DISTRICT FOR A DEVIATION FROM THE)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION)	2005-00542
4(4), REGARDING WATER STORAGE)	

O R D E R

On December 20, 2005, the Western Rockcastle Water District ("Western Rockcastle District") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Western Rockcastle District states in its application that its average daily water usage, including unaccounted-for water, is approximately 850,000 gallons, and that its current water storage capacity is 777,000 gallons. The Mt. Vernon Water Works, Western Rockcastle District's current water supplier, has agreed to supply up to 29,000,000 gallons of water per month, or approximately 966,666 gallons per day, and Western Rockcastle District may purchase an additional 10,000,000 gallons per month for an approximate total of 1,300,000 gallons per day.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Western Rockcastle District is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).

2. Because of the time needed to plan, finance, and construct water storage facilities, Western Rockcastle District should be given until December 20, 2011 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:


1. Western Rockcastle District is given until December 20, 2011 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).

2. Western Rockcastle District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to December 20, 2011.

Done at Frankfort, Kentucky, this 18th day of April, 2006.

By the Commission

ATTEST:



Executive Director